STONE & WEBSTER ENGINEERING CORPORATION

49 FEDERAL STREET, BOSTON, MASSACHUSETTS 02107

NEW YORK
BOSTON
CHICAGO
HOUSTON
LOS ANGELES
SAN FRANCISCO
SEATTLE
WASHINGTON, D. C.

DESIGN
CONSTRUCTION
REPORTS
APPRAISALS
EXAMINATIONS
CONSULTING
ENGINEERING

July 16, 1965

Kingsbury

SCE says this is a rather impersonal report

Mr. Joseph Kaminski, Jr.,
Insulator Department,
General Electric Company,
2525 Insulator Drive,
Baltimore, Maryland 21230.

J.O.No. 11028

RECEIVED
JUL 19 1965
MARKETING

Dear Sir:

RIV AND CORONA TESTS
INSULATOR-HARDWARE ASSEMBLIES
500 KV TRANSMISSION LINES
SOUTHERN CALIFORNIA EDISON COMPANY

We enclose copy of report entitled, "RIV and Corona Tests on Insulators and Hardware Assemblies for Southern California Edison Company 500 Kv System," which is approved as noted. Enclosed also is a draft of paragraph containing additional information which we wish to be included in the report.

We suggest that a separate ~~introductory page~~, dated and signed by you, be inserted to indicate submission of the report. We have indicated that the information contained in the general paragraph of Section 1 should be included on this "submission" page. We also suggest that you include name plate or other indentifying data for the major items of equipment used for testing; i.e., radio noise meter, signal generator, coupling capacitor, shielded cable, resistor and transformers. These data should be included in Section 1.

Please note that on the sketches in Section 4 we have indicated additional dimensions and data which should be included. We have also noted that the date of the test should be added to each curve.

Please make revisions as noted and additional changes as marked in the report and submit four copies for approval in accordance with procedure established for drawing approval.

Yours very truly,

R. E. Moran,
Project Engineer.

Enclosures